

Tent Permit Application



**Albuquerque Fire
Marshal's Office**
600 2nd St NW
Albuquerque, NM 87102
(505) 924-3611 *phone*
(505) 924-3619 *fax*

Approved Denied
Man # _____ Date _____
Case # _____
Officer Signature _____
Inspection Date _____
Inspection Time _____
Total Square Footage _____

Approved plans do not guarantee the issuance of a permit. Final inspection is required confirming the event coincides with the approved plans.

Event Name: _____
Event Location: _____

Event Contact Information

Contact Name: _____ Contact Phone: _____
Contact Email: _____ Emergency Phone: _____
Contact Address: _____
Event Start Date: _____ Event Start Time: _____
Event End Date: _____ Event End Time: _____

Permit Applicant Information

Contact Name: _____ Contact Phone: _____
Contact Email: _____ Emergency Phone: _____
Contact Address: _____

Tent Permit Requirements

Construction Documents: Detailed site plan for the assembly area shall be provided with each application for approval. The site plan shall indicate means of egress, seating arrangement, heating and electrical equipment, exit signs, fire extinguishers, cooking equipment, and exhibits. (Ordinance 105.4)

Location: Tents or canopies shall not be located within 20 feet of lot lines, vehicles, or generators. All dimensions shall be indicated on the site plan. (IFC 2403.8)

Display of Motor Vehicles: Vehicles and equipment used for display within or near tents shall have batteries disconnected, have less than ¼ tank of fuel, and tank openings shall be locked and sealed. Vehicles shall not obstruct the means of egress. (IFC 2404.18)

Propane Gas: Tents or canopies shall not be located within 10 feet of propane tanks less than 500 gallons. (IFC 2404.16.2.1)

Anchorage: Required Tents or Membrane Structures and their appurtenances shall be adequately roped, braced or anchored to withstand the elements of weather and prevent against collapsing. (IFC 2403.9)

Air Inflated Fun Jumps: Air inflated fun jumps shall be approved on the site plan. (IFC 2403.4 and IFC 2403.2)

Outdoor Assemblies: The fire code official shall establish an occupant load for tents and access controlled events. (IFC 2804.2)

Cooking: All cooking and warming devices shall be indicated on the floor plan. Cooking appliance approvals shall be granted on a case by case basis. (IFC 2404.15)

Vegetation And Waste: Combustible vegetation and waste shall be cleared 30 feet back from tents or canopies. A description of the floor surface surrounding the tent or canopy and the floor within the tent or canopy shall be indicated on the floor plan. (IFC 2404.21)

Combustible Material: Hay, straw, shavings or similar combustible materials shall not be located within any tent or

canopy with an occupant load greater than 49 and or a square footage exceeding 750 square feet. A description of the floor surface inside the tent or canopy is required. (IFC 2404.5)

Clearances: There shall be a minimum clearance of 3 feet between tent walls and tent contents. All dimensions shall be indicated on the floor plan. (IFC 2404.11)

Smoking: Approved "No Smoking" signs shall be posted and indicated on the floor plan. Smoking shall be prohibited. (IFC 2404.6)

Generators: All generators shall be isolated from the public by fencing or by other approved means, a minimum of 3Ft. from the generator. One 3A-40BC Fire Extinguisher is required per generator. Generator indications are required on the site plan. (IFC 2404.19)

Fire Extinguishers: A Fire Extinguisher shall be provided for every 1500 square feet within the space. Travel distance to a Fire Extinguisher shall not exceed 75 feet. Extinguishers shall be indicated on the floor plan. (IFC 2404.12)

Required Exits: Equal or greater than: [150sqft 2 exits are required] [3,000sqft 3 exits are required] [7,500sqft 4 exits are required] [15,000sqft 5 exits are required] [30,000sqft 6 exits are required]. Exits must be spaced appropriately. (IFC 2403.12)

Exits: Exit openings shall be contrasting in color and be free sliding. Tent side walls or open wall canopies shall be indicated on the plans. (IFC 2403.12.3)

Exit Sign Illumination and Emergency Lighting: Exit sign illumination and emergency lighting are required when the occupant load exceeds *49*. (IFC 2403.12.6)

Extension Cords: Only approved UL, FM, or NRTL, three prong, grounded extension cords are permitted. Frayed or taped wire is prohibited. (IFC 605.5)

Tent Material: All tent material shall meet "State of California Fire Marshal's Office" standards as per IFC Section 2404.2, NFPA 701, or CPAI84. (IFC 2404.2)

Access: All Fire Hydrants and Fire Department appliances shall be free from obstructions. Fire Department access roads shall be a minimum of 20 feet. (IFC 2403.8.1)

Chairs: Non-fixed chairs exceeding 200 shall be fastened together in groups no less than three or securely fastened to the floor. (IFC 1028.12)

Permits: All tents require permits. All canopies which exceed 400 square feet shall not be erected without obtaining a permit from our office.

Tent Fees: [401-1500sqft \$100] [1501-3000sqft \$150] [3001-6000sqft \$200] [6001-9000sqft \$250] [+9001sqft \$300]

Additional Fees: Additional fees may apply to all after hour inspections.

Inspections: Inspection times shall be scheduled within four hours of the event opening. All electrical equipment, catering devices, tables, chairs, and merchandise shall be set in place prior to inspection.

The undersigned hereby acknowledges that all requirements indicated above must be adhered to in order for this application to be accepted. The standards specified above are the minimal requirements which the applicant is not limited to. Additional Fire Codes may apply during initial inspection if unforeseeable circumstances arise. An approved plot plan or floor plan does not guarantee the issuance of a permit. Final inspection is required confirming the event coincides with both the approved plot plan and floor plan. All disapprovals will be indicated on the tops of each page and all violations will be indicated with a check mark on this disclaimer. All information must be submitted to process this application. Revised 11/15/12

Event Contact Name: _____
(Please Print)

Phone Number: _____

Event Contact Signature: _____

Date: _____

Permit Applicant Name: _____
(Please Print)

Phone Number: _____

Permit Applicant Signature: _____

Date: _____

Please include site plan guide (below) on any site plans.

Legend	Officer Comments	Tent Permit Application												
<table><tr><td> ILLUMINATED EXIT SIGN</td><td> FIRE EXTNGUISHER</td></tr><tr><td> EMERGENCY LIGHTING</td><td> NO SMOKING SIGNS</td></tr><tr><td> COMBINATION UNIT</td><td>..... NO SIDE WALL</td></tr><tr><td> EXIT OPENING</td><td>—— TENT SIDE WALL</td></tr><tr><td> FIRE HYDRANT</td><td> GENERATOR / MOTOR</td></tr><tr><td> FIRE DEPT CONNECTION</td><td> LIQUEFIED PETROLEUM GAS</td></tr></table>	 ILLUMINATED EXIT SIGN	 FIRE EXTNGUISHER	 EMERGENCY LIGHTING	 NO SMOKING SIGNS	 COMBINATION UNIT NO SIDE WALL	 EXIT OPENING	—— TENT SIDE WALL	 FIRE HYDRANT	 GENERATOR / MOTOR	 FIRE DEPT CONNECTION	 LIQUEFIED PETROLEUM GAS		<p>Tent Permit Application</p> <p><input type="checkbox"/> Approved <input type="checkbox"/> Denied</p> <p>Man # _____</p> <p>Date _____</p> <p>Case # _____</p> <p>Officer Signature _____</p>
 ILLUMINATED EXIT SIGN	 FIRE EXTNGUISHER													
 EMERGENCY LIGHTING	 NO SMOKING SIGNS													
 COMBINATION UNIT NO SIDE WALL													
 EXIT OPENING	—— TENT SIDE WALL													
 FIRE HYDRANT	 GENERATOR / MOTOR													
 FIRE DEPT CONNECTION	 LIQUEFIED PETROLEUM GAS													