FIRE CHIEF

PROJECT INFORMATION

Paul Dow 11500 Sunset Gardens Rd SW Albuquerque, NM 87121



FIRE MARSHALGene Gallegos
724 Silver SW
Albuquerque, NM 87102

REVISED 3/21/18

OPEN BURN: FIRE DEPARTMENT FLOOR PLAN/SITE PLAN CRITERIA

Event Name				Event Address	Case Number	
APPLICATION PAGE 1 AND 2 CHECK LIST PASS FAIL REQUIREMENT CODE REF.						
	PASS	FAIL	REQUIREMENT INCRECTION DATE: Inspection times shall be scheduled within a reasonable time prior to the event enging			
1			INSPECTION DATE: Inspection times shall be scheduled within a reasonable time prior to the event opening.			
2			FIRST PAGE INFO: All of the fields on the first page are required to be filled. Inspection times are typically 1 hour prior to the event, but can be as early as 4 hours prior to the event.			
	Ш	Ш				
3			REQUIREMENTS PAGE: The signature is required at the bottom of the requirements page.			
	Ш		REQUIREMENTS PAGE: The signature is required at the bottom of the requirements page.			
SITE PLAN CHECK LIST						
	PASS	FAIL	REQUIREMENT			
	CONSTRUCTION DOCUMENTS: Site plan shall be electronically drawn. A color aerial view ma) IFC 105.4.1	
1	Ш		with the burn operation and information overlaid onto the map is required.			
			LABELING: Label the area of use. Indicate the pit size. This can be accomplished with a site map legend.			
2			LABELING. Laber the area of use. Indicate the pit size. This can be accomplished with a site map regent.			
			LOCATION: Identify the distances from structures and combustible materials. Indicate on the plan, the location of the			
3			operation.			
					edge IFC 105.4.1	
4			PERIMITER: Indicate the perimeter on the plan. A good rule of thumb for perimeter size is 5 to 6ft from the edge of the burn operation in all directions.			
4						
_			WATER SOURCE: Bon fires require a water source and constant attendance. Indicate the water source on the			
5	Ш		plan.			
FLOOR PLAN CHECK LIST						
	PASS	FAIL	REQUIREMENT		CODE REF.	
				The burn operation requires an individual floor plan. The floor plan shall be	IFC 105.4.1	
6			electronically drawn.			
			OPEN FLAME APPARATUS	S: Open flame apparatus such as a roaster, forge, or glass blowing shall be indicate	d IFC 105.4.1	
7			and labeled on the floor p			
8	П			r Legend may be required on the floor plan/ siteplan defining all of the symbols and	IFC 105.4.1	
0			abbreviations.	MARCO Cina Cuting with an aball be associated within the graving star of the bury space	ation IFC 906.1	
			FIRE EXTINGUISHERS: A 3A40BC Fire Extinguisher shall be provided within the perimeter of the burn operation and no closer than 5ft. Extinguishers shall be indicated and labeled on the floor plan.			
9			and no closer than sit.	temparation and table and table and table and the most plant		
10			PROPANE: The propane for	uel shall be indicated and labeled on the plan.	IFC 3183.1	
10	Ш					
11			PERIMITER: Indicate the p	perimeter on the floor plan. The dimensions also need to be indicated on the floor p	olan. IFC 105.4.1	

Fire Marshal's Office Plans Check Division