



EMSL Analytical, Inc.

464 McCormick Street San Leandro, CA 94577
Tel/Fax: (510) 895-3675 / (510) 895-3680
<http://www.EMSL.com> / sanleandrolab@emsl.com

EMSL Order: 092307273
Customer ID: SWAI50
Customer PO: 23MR-15621-7291
Project ID:

Attention: Kendra West
Southwest Abatement, Inc,
4609 S. Kinney St. SE
Albuquerque, NM 87105

Phone: (505) 873-2967
Fax: (505) 873-1242
Received Date: 04/03/2023 08:45 AM
Analysis Date: 04/03/2023
Collected Date: 03/27/2023

Project: 23MR-15621-7291 - GMC GATEWAY PHASE 1

Test Report: Fiber Count by Phase Contrast Microscopy (PCM), NIOSH 7400 Method - A Rules, Revision 3, Issue 3, 6/15/2019

Sample	Location	Sample Date	Volume (L)	Fibers	Fields	LOD (fib/cc)	Fibers/mm ²	Fibers/cc	Notes
7291-2703-P01	JOSEPH SALVADOR - FLOOR TILE	03/27/2023	180	<5.5	100	0.0150	<7.01	<0.0150	
092307273-0001									
7291-2703-E01	JESUS SALAZAR - FLOOR TILE	03/27/2023	60	<5.5	100	0.0449	<7.01	<0.0449	
092307273-0002									
BLANK OPEN	BLANK	03/27/2023		<5.5	100		<7.01		Field Blank
092307273-0003									
BLANK CLOSED	BLANK	03/27/2023		<5.5	100		<7.01		Field Blank
092307273-0004									

The results reported have been blank corrected as applicable.

Analyst(s):

Matthew Wilson PCM 4

Cecilia Yu, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Limit of detection is 7 fibers/mm². Fiber counts outside the recommended fiber density range of the method (100-1300 f/mm²) have greater than optimal variability and are probably biased. Field blank results, when available, are used to blank correct results. NIOSH 7400 requires field blanks be submitted at a rate of 10%, with a minimum of 2 per set. Measurement of uncertainty available upon request. The results in this report meet all requirements of the NELAC standards unless otherwise noted. Intra-laboratory Sr values: 5-20 fibers = 0.33, 21-50 fibers = 0.21, 51-100 fibers = 0.12. Inter-laboratory Sr values (Average of EMSL round robin data) = 0.35.

Samples analyzed by EMSL Analytical, Inc San Leandro, CA AIHA LAP, LLC-IHLAP Accredited #101748

Initial report from: 04/03/2023 03:25 PM



EMSL Analytical, Inc.

464 McCormick Street San Leandro, CA 94577
Tel/Fax: (510) 895-3675 / (510) 895-3680
<http://www.EMSL.com> / sanleandrolab@emsl.com

EMSL Order: 092307949
Customer ID: SWAI50
Customer PO: 23MR-15621-7291
Project ID:

Attention: Sampling
Southwest Abatement, Inc,
4609 S. Kinney St. SE
Albuquerque, NM 87105

Phone: (505) 873-2967
Fax: (505) 873-1242
Received Date: 04/11/2023 08:45 AM
Analysis Date: 04/12/2023
Collected Date: 03/27/2023

Project: 23MR-15621-7291 - GMC GATEWAY PHASE 1

Test Report: Fiber Count by Phase Contrast Microscopy (PCM), NIOSH 7400 Method - A Rules, Revision 3, Issue 3, 6/15/2019

Sample	Location	Sample Date	Volume (L)	Fibers	Fields	LOD (fib/cc)	Fibers/mm ²	Fibers/cc	Notes
7291-2703-P01	JOSEPH SALVADOR - BLACK MASTIC	03/27/2023	130	<5.5	100	0.0207	<7.01	<0.0207	
092307949-0001									
7291-2703-E01	ORLANDO LOPEZ - BLACK MASTIC	03/27/2023	60	<5.5	100	0.0449	<7.01	<0.0449	
092307949-0002									
BLANK OPEN	FIELD BLANK	03/27/2023		<5.5	100		<7.01		Field Blank
092307949-0003									
BLANK CLOSED	FIELD BLANK	03/27/2023		<5.5	100		<7.01		Field Blank
092307949-0004									

The results reported have been blank corrected as applicable.

Analyst(s):

Matthew Wilson PCM 4

Cecilia Yu, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Limit of detection is 7 fibers/mm². Fiber counts outside the recommended fiber density range of the method (100-1300 f/mm²) have greater than optimal variability and are probably biased. Field blank results, when available, are used to blank correct results. NIOSH 7400 requires field blanks be submitted at a rate of 10%, with a minimum of 2 per set. Measurement of uncertainty available upon request. The results in this report meet all requirements of the NELAC standards unless otherwise noted. Intra-laboratory Sr values: 5-20 fibers = 0.33, 21-50 fibers = 0.21, 51-100 fibers = 0.12. Inter-laboratory Sr values (Average of EMSL round robin data) = 0.35.

Samples analyzed by EMSL Analytical, Inc San Leandro, CA AIHA LAP, LLC-IHLAP Accredited #101748

Initial report from: 04/12/2023 09:03 AM



EMSL Analytical, Inc.

464 McCormick Street San Leandro, CA 94577
Tel/Fax: (510) 895-3675 / (510) 895-3680
<http://www.EMSL.com> / sanleandrolab@emsl.com

EMSL Order: 092307957
Customer ID: SWAI50
Customer PO:
Project ID:

Attention: Kendra West
Southwest Abatement, Inc,
4609 S. Kinney St. SE
Albuquerque, NM 87105

Phone: (505) 873-2967
Fax: (505) 873-1242
Received Date: 04/11/2023 08:45 AM
Analysis Date: 04/11/2023
Collected Date: 03/28/2023

Project: 23MR - 15621-7291 - GMC GATEWAY PHASE 1

Test Report: Fiber Count by Phase Contrast Microscopy (PCM), NIOSH 7400 Method - A Rules, Revision 3, Issue 3, 6/15/2019

Sample	Location	Sample Date	Volume (L)	Fibers	Fields	LOD (fib/cc)	Fibers/mm ²	Fibers/cc	Notes
7291-2803-P02 092307957-0001	BLACK MASTIC	03/28/2023	900	<5.5	100	0.0030	<7.01	<0.0030	
7291-2803-E02 092307957-0002	BLACK MASTIC	03/28/2023	60	<5.5	100	0.0449	<7.01	<0.0449	
BLANK OPEN 092307957-0003	BLANK	03/28/2023		<5.5	100		<7.01		Field Blank
BLANK CLOSED 092307957-0004	BLANK	03/28/2023		<5.5	100		<7.01		Field Blank

The results reported have been blank corrected as applicable.

Analyst(s):

Matthew Wilson PCM 4

Cecilia Yu, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Limit of detection is 7 fibers/mm². Fiber counts outside the recommended fiber density range of the method (100-1300 f/mm²) have greater than optimal variability and are probably biased. Field blank results, when available, are used to blank correct results. NIOSH 7400 requires field blanks be submitted at a rate of 10%, with a minimum of 2 per set. Measurement of uncertainty available upon request. The results in this report meet all requirements of the NELAC standards unless otherwise noted. Intra-laboratory Sr values: 5-20 fibers = 0.33, 21-50 fibers = 0.21, 51-100 fibers = 0.12. Inter-laboratory Sr values (Average of EMSL round robin data) = 0.35.
Samples analyzed by EMSL Analytical, Inc San Leandro, CA AIHA LAP, LLC-IHLAP Accredited #101748

Initial report from: 04/11/2023 02:09 PM



EMSL Analytical, Inc.

464 McCormick Street San Leandro, CA 94577

Tel/Fax: (510) 895-3675 / (510) 895-3680

<http://www.EMSL.com / sanleandrolab@emsl.com>

EMSL Order: 092307961

Customer ID: SWAI50

Customer PO:

Project ID:

Attention: Sampling
Southwest Abatement, Inc,
4609 S. Kinney St. SE
Albuquerque, NM 87105

Phone: (505) 873-2967
Fax: (505) 873-1242
Received Date: 04/11/2023 08:45 AM
Analysis Date: 04/11/2023
Collected Date: 03/29/2023

Project: 23MR-15621-7291 - GMC GATEWAY PHASE 1

Test Report: Fiber Count by Phase Contrast Microscopy (PCM), NIOSH 7400 Method - A Rules, Revision 3, Issue 3, 6/15/2019

Sample	Location	Sample Date	Volume (L)	Fibers	Fields	LOD (fib/cc)	Fibers/mm ²	Fibers/cc	Notes
7291-2903-P03 092307961-0001	BLACK MASTIC	03/29/2023	900	<5.5	100	0.0030	<7.01	<0.0030	
7291-2903-E03 092307961-0002	BLACK MASTIC	03/29/2023	60	<5.5	100	0.0449	<7.01	<0.0449	
BLANK OPEN 092307961-0003	BLANK	03/29/2023		<5.5	100		<7.01		Field Blank
BLANK CLOSED 092307961-0004	BLANK	03/29/2023		<5.5	100		<7.01		Field Blank

The results reported have been blank corrected as applicable.

Analyst(s):

Matthew Wilson PCM 4

Cecilia Yu, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Limit of detection is 7 fibers/mm². Fiber counts outside the recommended fiber density range of the method (100-1300 f/mm²) have greater than optimal variability and are probably biased. Field blank results, when available, are used to blank correct results. NIOSH 7400 requires field blanks be submitted at a rate of 10%, with a minimum of 2 per set. Measurement of uncertainty available upon request. The results in this report meet all requirements of the NELAC standards unless otherwise noted. Intra-laboratory Sr values: 5-20 fibers = 0.33, 21-50 fibers = 0.21, 51-100 fibers = 0.12. Inter-laboratory Sr values (Average of EMSL round robin data) = 0.35.

Samples analyzed by EMSL Analytical, Inc San Leandro, CA AIHA LAP, LLC-IHLAP Accredited #101748

Initial report from: 04/11/2023 02:31 PM



EMSL Analytical, Inc.

464 McCormick Street San Leandro, CA 94577
Tel/Fax: (510) 895-3675 / (510) 895-3680
<http://www.EMSL.com> / sanleandrolab@emsl.com

EMSL Order: 092307964
Customer ID: SWAI50
Customer PO: 23MR-15621-7291
Project ID:

Attention: Sampling
Southwest Abatement, Inc,
4609 S. Kinney St. SE
Albuquerque, NM 87105

Phone: (505) 873-2967
Fax: (505) 873-1242
Received Date: 04/11/2023 08:45 AM
Analysis Date: 04/12/2023
Collected Date: 03/30/2023

Project: 23MR-15621-7291 - GMC GATEWAY PHASE 1

Test Report: Fiber Count by Phase Contrast Microscopy (PCM), NIOSH 7400 Method - A Rules, Revision 3, Issue 3, 6/15/2019

Sample	Location	Sample Date	Volume (L)	Fibers	Fields	LOD (fib/cc)	Fibers/mm ²	Fibers/cc	Notes
7291-3003-P04	ORLANDO LOPEZ - BLACK MASTIC	03/30/2023	900	<5.5	100	0.0030	<7.01	<0.0030	
092307964-0001									
7291-3003-E04	JOSEPH SALVADOR - BLACK MASTIC	03/30/2023	60	<5.5	100	0.0449	<7.01	<0.0449	
092307964-0002									
BLANK OPEN	FIELD BLANK	03/30/2023		<5.5	100		<7.01		Field Blank
092307964-0003									
BLANK CLOSED	FIELD BLANK	03/30/2023		<5.5	100		<7.01		Field Blank
092307964-0004									

The results reported have been blank corrected as applicable.

Analyst(s):

Matthew Wilson PCM 4

Cecilia Yu, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Limit of detection is 7 fibers/mm². Fiber counts outside the recommended fiber density range of the method (100-1300 f/mm²) have greater than optimal variability and are probably biased. Field blank results, when available, are used to blank correct results. NIOSH 7400 requires field blanks be submitted at a rate of 10%, with a minimum of 2 per set. Measurement of uncertainty available upon request. The results in this report meet all requirements of the NELAC standards unless otherwise noted. Intra-laboratory Sr values: 5-20 fibers = 0.33, 21-50 fibers = 0.21, 51-100 fibers = 0.12. Inter-laboratory Sr values (Average of EMSL round robin data) = 0.35.

Samples analyzed by EMSL Analytical, Inc San Leandro, CA AIHA LAP, LLC-IHLAP Accredited #101748

Initial report from: 04/12/2023 09:20 AM



EMSL Analytical, Inc.

464 McCormick Street San Leandro, CA 94577

Tel/Fax: (510) 895-3675 / (510) 895-3680

<http://www.EMSL.com> / sanleandrolab@emsl.com

EMSL Order: 092307963

Customer ID: SWAI50

Customer PO:

Project ID:

Attention: Sampling
Southwest Abatement, Inc,
4609 S. Kinney St. SE
Albuquerque, NM 87105

Phone: (505) 873-2967
Fax: (505) 873-1242
Received Date: 04/11/2023 08:45 AM
Analysis Date: 04/12/2023
Collected Date: 03/31/2023

Project: 23MR-15621-7291 - GMC GATEWAY PHASE 1

Test Report: Fiber Count by Phase Contrast Microscopy (PCM), NIOSH 7400 Method - A Rules, Revision 3, Issue 3, 6/15/2019

Sample	Location	Sample Date	Volume (L)	Fibers	Fields	LOD (fib/cc)	Fibers/mm ²	Fibers/cc	Notes
7291-3103-P05	JESUS SALAZAR - BLACK MASTIC	03/31/2023	900	<5.5	100	0.0030	<7.01	<0.0030	
092307963-0001									
7291-3103-E05	ORLANDO LOPEZ - BLACK MASTIC	03/31/2023	60	<5.5	100	0.0449	<7.01	<0.0449	
092307963-0002									
BLANK OPEN	BLANK	03/31/2023		<5.5	100		<7.01		Field Blank
092307963-0003									
BLANK CLOSED	BLANK	03/31/2023		<5.5	100		<7.01		Field Blank
092307963-0004									

The results reported have been blank corrected as applicable.

Analyst(s):

Matthew Wilson PCM 4

Cecilia Yu, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Limit of detection is 7 fibers/mm². Fiber counts outside the recommended fiber density range of the method (100-1300 f/mm²) have greater than optimal variability and are probably biased. Field blank results, when available, are used to blank correct results. NIOSH 7400 requires field blanks be submitted at a rate of 10%, with a minimum of 2 per set. Measurement of uncertainty available upon request. The results in this report meet all requirements of the NELAC standards unless otherwise noted. Intra-laboratory Sr values: 5-20 fibers = 0.33, 21-50 fibers = 0.21, 51-100 fibers = 0.12. Inter-laboratory Sr values (Average of EMSL round robin data) = 0.35.

Samples analyzed by EMSL Analytical, Inc San Leandro, CA AIHA LAP, LLC-IHLAP Accredited #101748

Initial report from: 04/12/2023 09:09 AM



EMSL Analytical, Inc.

464 McCormick Street San Leandro, CA 94577

Tel/Fax: (510) 895-3675 / (510) 895-3680

<http://www.EMSL.com> / sanleandrolab@emsl.com

EMSL Order: 092308000
Customer ID: SWA150
Customer PO: 23MR-15621-7291
Project ID:

Attention: Sampling
Southwest Abatement, Inc,
4609 S. Kinney St. SE
Albuquerque, NM 87105

Phone: (505) 873-2967
Fax: (505) 873-1242
Received Date: 04/11/2023 08:45 AM
Analysis Date: 04/12/2023
Collected Date: 04/03/2023

Project: 23MR-15621-7291 - GMC GATEWAY PHASE 1

Test Report: Fiber Count by Phase Contrast Microscopy (PCM), NIOSH 7400 Method - A Rules, Revision 3, Issue 3, 6/15/2019

Sample	Location	Sample Date	Volume (L)	Fibers	Fields	LOD (fib/cc)	Fibers/mm ²	Fibers/cc	Notes
7291-0304-P06	JOSEPH SALVADOR - BLACK MASTIC	04/03/2023	360	<5.5	100	0.0075	<7.01	<0.0075	
<i>092308000-0001</i>									
7291-0304-E06	JESUS SALAZAR - BLACK MASTIC	04/03/2023	60	<5.5	100	0.0449	<7.01	<0.0449	
<i>092308000-0002</i>									
BLANK OPEN	FIELD BLANK	04/03/2023		<5.5	100		<7.01		Field Blank
<i>092308000-0003</i>									
BLANK CLOSED	FIELD BLANK	04/03/2023		<5.5	100		<7.01		Field Blank
<i>092308000-0004</i>									

The results reported have been blank corrected as applicable.

Analyst(s):

Matthew Wilson PCM 4

Cecilia Yu, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Limit of detection is 7 fibers/mm². Fiber counts outside the recommended fiber density range of the method (100-1300 f/mm²) have greater than optimal variability and are probably biased. Field blank results, when available, are used to blank correct results. NIOSH 7400 requires field blanks be submitted at a rate of 10%, with a minimum of 2 per set. Measurement of uncertainty available upon request. The results in this report meet all requirements of the NELAC standards unless otherwise noted. Intra-laboratory Sr values: 5-20 fibers = 0.33, 21-50 fibers = 0.21, 51-100 fibers = 0.12. Inter-laboratory Sr values (Average of EMSL round robin data) = 0.35.

Samples analyzed by EMSL Analytical, Inc San Leandro, CA AIHA LAP, LLC-IHLAP Accredited #101748

Initial report from: 04/12/2023 08:35 AM



EMSL Analytical, Inc.

464 McCormick Street San Leandro, CA 94577
Tel/Fax: (510) 895-3675 / (510) 895-3680
<http://www.EMSL.com> / sanleandrolab@emsl.com

EMSL Order: 092308142
Customer ID: SWAI50
Customer PO: 23MR-15621-7291
Project ID:

Attention: Sampling
Southwest Abatement, Inc,
4609 S. Kinney St. SE
Albuquerque, NM 87105

Phone: (505) 873-2967
Fax: (505) 873-1242
Received Date: 04/13/2023 09:15 AM
Analysis Date: 04/13/2023
Collected Date: 04/04/2023

Project: 23MR-15621-7291 - GMC GATEWAY PHASE 1

Test Report: Fiber Count by Phase Contrast Microscopy (PCM), NIOSH 7400 Method - A Rules, Revision 3, Issue 3, 6/15/2019

Sample	Location	Sample Date	Volume (L)	Fibers	Fields	LOD (fib/cc)	Fibers/mm ²	Fibers/cc	Notes
7291-0404-P07	JESUS SALAZAR - BLACK MASTIC	04/04/2023	180	<5.5	100	0.0150	<7.01	<0.0150	
092308142-0001									
7291-0404-E07	ORLANDO LOPEZ - BLACK MASTIC	04/04/2023	60	<5.5	100	0.0449	<7.01	<0.0449	
092308142-0002									
BLANK OPEN	FIELD BLANK	04/04/2023		<5.5	100		<7.01		Field Blank
092308142-0003									
BLANK CLOSED	FIELD BLANK	04/04/2023		<5.5	100		<7.01		Field Blank
092308142-0004									

The results reported have been blank corrected as applicable.

Analyst(s):

Matthew Wilson PCM 4

Cecilia Yu, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Limit of detection is 7 fibers/mm². Fiber counts outside the recommended fiber density range of the method (100-1300 f/mm²) have greater than optimal variability and are probably biased. Field blank results, when available, are used to blank correct results. NIOSH 7400 requires field blanks be submitted at a rate of 10%, with a minimum of 2 per set. Measurement of uncertainty available upon request. The results in this report meet all requirements of the NELAC standards unless otherwise noted. Intra-laboratory Sr values: 5-20 fibers = 0.33, 21-50 fibers = 0.21, 51-100 fibers = 0.12. Inter-laboratory Sr values (Average of EMSL round robin data) = 0.35.
Samples analyzed by EMSL Analytical, Inc San Leandro, CA AIHA LAP, LLC-IHLAP Accredited #101748

Initial report from: 04/13/2023 03:20 PM



EMSL Analytical, Inc.

464 McCormick Street San Leandro, CA 94577

Tel/Fax: (510) 895-3675 / (510) 895-3680

<http://www.EMSL.com> / sanleandrolab@emsl.com

EMSL Order: 092308145

Customer ID: SWAI50

Customer PO: 23MR-15621-7291

Project ID:

Attention: Sampling
Southwest Abatement, Inc,
4609 S. Kinney St. SE
Albuquerque, NM 87105

Phone: (505) 873-2967
Fax: (505) 873-1242
Received Date: 04/13/2023 09:15 AM
Analysis Date: 04/13/2023
Collected Date: 04/05/2023

Project: 23MR-15621-7291 - GMC GATEWAY PHASE 1

Test Report: Fiber Count by Phase Contrast Microscopy (PCM), NIOSH 7400 Method - A Rules, Revision 3, Issue 3, 6/15/2019

Sample	Location	Sample Date	Volume (L)	Fibers	Fields	LOD (fib/cc)	Fibers/mm ²	Fibers/cc	Notes
7291-0504-P08	JOSEPH SALVADOR - BLACK MASTIC	04/05/2023	900	<5.5	100	0.0030	<7.01	<0.0030	
092308145-0001									
7291-0504-E08	JESUS SALAZAR - BLACK MASTIC	04/05/2023	60	<5.5	100	0.0449	<7.01	<0.0449	
092308145-0002									
BLANK OPEN	FIELD BLANK	04/05/2023		<5.5	100		<7.01		Field Blank
092308145-0003									
BLANK CLOSED	FIELD BLANK	04/05/2023		<5.5	100		<7.01		Field Blank
092308145-0004									

The results reported have been blank corrected as applicable.

Analyst(s):

Matthew Wilson PCM 4

Cecilia Yu, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Limit of detection is 7 fibers/mm². Fiber counts outside the recommended fiber density range of the method (100-1300 f/mm²) have greater than optimal variability and are probably biased. Field blank results, when available, are used to blank correct results. NIOSH 7400 requires field blanks be submitted at a rate of 10%, with a minimum of 2 per set. Measurement of uncertainty available upon request. The results in this report meet all requirements of the NELAC standards unless otherwise noted. Intra-laboratory Sr values: 5-20 fibers = 0.33, 21-50 fibers = 0.21, 51-100 fibers = 0.12. Inter-laboratory Sr values (Average of EMSL round robin data) = 0.35.

Samples analyzed by EMSL Analytical, Inc San Leandro, CA AIHA LAP, LLC-IHLAP Accredited #101748

Initial report from: 04/13/2023 03:13 PM



EMSL Analytical, Inc.

464 McCormick Street San Leandro, CA 94577
Tel/Fax: (510) 895-3675 / (510) 895-3680
<http://www.EMSL.com> / sanleandrolab@emsl.com

EMSL Order: 092308158
Customer ID: SWAI50
Customer PO: 23MR-15621-7291
Project ID:

Attention: Sampling
Southwest Abatement, Inc.
4609 S. Kinney St. SE
Albuquerque, NM 87105

Phone: (505) 873-2967
Fax: (505) 873-1242
Received Date: 04/13/2023 09:15 AM
Analysis Date: 04/13/2023
Collected Date: 04/06/2023

Project: 23MR-15621-7291 - GMC GATEWAY PHASE 1

Test Report: Fiber Count by Phase Contrast Microscopy (PCM), NIOSH 7400 Method - A Rules, Revision 3, Issue 3, 6/15/2019

Sample	Location	Sample Date	Volume (L)	Fibers	Fields	LOD (fib/cc)	Fibers/mm ²	Fibers/cc	Notes
7291-0604-P09	ORLANDO LOPEZ - BLACK MASTIC	04/06/2023	900	<5.5	100	0.0030	<7.01	<0.0030	
<i>092308158-0001</i>									
7291-0604-E09	JOSEPH SALVADOR - BLACK MASTIC	04/06/2023	60	<5.5	100	0.0449	<7.01	<0.0449	
<i>092308158-0002</i>									
BLANK OPEN	FIELD BLANK	04/06/2023		<5.5	100		<7.01		Field Blank
<i>092308158-0003</i>									
BLANK CLOSED	FIELD BLANK	04/06/2023		<5.5	100		<7.01		Field Blank
<i>092308158-0004</i>									

The results reported have been blank corrected as applicable.

Analyst(s):

Matthew Wilson PCM 4

Cecilia Yu, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Limit of detection is 7 fibers/mm². Fiber counts outside the recommended fiber density range of the method (100-1300 f/mm²) have greater than optimal variability and are probably biased. Field blank results, when available, are used to blank correct results. NIOSH 7400 requires field blanks be submitted at a rate of 10%, with a minimum of 2 per set. Measurement of uncertainty available upon request. The results in this report meet all requirements of the NELAC standards unless otherwise noted. Intra-laboratory Sr values: 5-20 fibers = 0.33, 21-50 fibers = 0.21, 51-100 fibers = 0.12. Inter-laboratory Sr values (Average of EMSL round robin data) = 0.35.
Samples analyzed by EMSL Analytical, Inc San Leandro, CA AIHA LAP, LLC-IHLAP Accredited #101748

Initial report from: 04/13/2023 03:32 PM



EMSL Analytical, Inc.

464 McCormick Street San Leandro, CA 94577
Tel/Fax: (510) 895-3675 / (510) 895-3680
<http://www.EMSL.com> / sanleandrolab@emsl.com

EMSL Order: 092308939
Customer ID: SWAI50
Customer PO: 23MR-15621-7291
Project ID:

Attention: Sampling
Southwest Abatement, Inc,
4609 S. Kinney St. SE
Albuquerque, NM 87105

Phone: (505) 873-2967
Fax: (505) 873-1242
Received Date: 04/24/2023 09:00 AM
Analysis Date: 04/25/2023
Collected Date: 04/07/2023

Project: 23MR-15621-7291 - GMC GATEWAY PHASE 1

Test Report: Fiber Count by Phase Contrast Microscopy (PCM), NIOSH 7400 Method - A Rules, Revision 3, Issue 3, 6/15/2019

Sample	Location	Sample Date	Volume (L)	Fibers	Fields	LOD (fib/cc)	Fibers/mm ²	Fibers/cc	Notes
7291-0704-P10	ORLANDO LOPEZ - BLACK MASTIC	04/07/2023	600	<5.5	100	0.0045	<7.01	<0.0045	
092308939-0001									
7291-0704-E10	JESUS SALAZAR - BLACK MASTIC	04/07/2023	60	<5.5	100	0.0449	<7.01	<0.0449	
092308939-0002									
BLANK OPEN	BLANK OPEN	04/07/2023		<5.5	100		<7.01		Field Blank
092308939-0003									
BLANK CLOSED	BLANK CLOSED	04/07/2023	0	<5.5	100		<7.01		Field Blank
092308939-0004									

The results reported have been blank corrected as applicable.

Analyst(s):

Matthew Wilson PCM 4

Cecilia Yu, Laboratory Manager
or other Approved Signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. Limit of detection is 7 fibers/mm². Fiber counts outside the recommended fiber density range of the method (100-1300 f/mm²) have greater than optimal variability and are probably biased. Field blank results, when available, are used to blank correct results. NIOSH 7400 requires field blanks be submitted at a rate of 10%, with a minimum of 2 per set. Measurement of uncertainty available upon request. The results in this report meet all requirements of the NELAC standards unless otherwise noted. Intra-laboratory Sr values: 5-20 fibers = 0.33, 21-50 fibers = 0.21, 51-100 fibers = 0.12. Inter-laboratory Sr values (Average of EMSL round robin data) = 0.35.

Samples analyzed by EMSL Analytical, Inc San Leandro, CA AIHA LAP, LLC-IHLAP Accredited #101748

Initial report from: 04/25/2023 08:46 AM